

Bill of Quantity
for

Provision of Grid Chemical Copper Earthing System for Entire nanotechnology Buildings

Sl. No.	Description of Item	Unit	Qty.	Rate in Figure (in Rs.)	Rate in Word	Amount (Rs.)
1	PART-A					
1	Providing and fixing 25mm X 5mm copper strip in 40mm dia GI pipe from earth electrode including connection with brass nut, bolt, spring, washer excation and re-filling etc. as required	mtr	160			
2	Providing, laying and fixing following dia G.I pipe (medium class) in ground complete with G.I fittings including trenching (75cm deep) and re-filling etc as required					
	50mm dia	mtr	40			
	PART-B					
3	Supply, Installation, testing and commissioning of copper chemical earthing system to achieve earth resistance value of the earthing system below 1 ohm with 80mm dia, 3 meter length MF pure copper earth electrode, suitable coupler, clamps, pit cover, high quality earth enhancing compound etc as required. Make JVM LPS Ltd (including 50KG Compound)	nos	4.00			
TOTAL AMOUNT						
Discount @%, if any						
GRAND TOTAL						

Seal
Date :

Signature of the Tenderer